



+61 (0)7 3808 8115
+61 413 123 520

Your home for high quality Terminal Insulators and Electro Mechanical components.

TEST SUMMARY - 74312 SERIES

74312 SERIES INFORMATION

The 74312 Series is a collection of large 4 point busbars, using 1/8" brass bus, and 5/16" posts. There are colour and post length differences, but the core 74312 model does not change.




TESTING EQUIPMENT

Electrical Testing Unit - Elektro-Automatik B-20080-340
Data Capture Device - DataQ DI-4718-B
Cables - 4/0 guage
Test Run Date - Feb 6, 2026



TEST RESULTS



TESTING SUMMARY:

Current at 200a stays right at 50c, current at 250a climbs to 63c. Running at 250a or above would require greater than 60c cabling. With 105c cabling, 350a can be maintained without reaching 100c.

SALES@VTEAUSTRALIA.COM

WWW.VTEAUSTRALIA.COM

